

**HOLLAND RIVERSIDE MARINA**

**P.O. BOX 622**

**KNIGHTSEN, CALIFORNIA 94548**

95C  
RECEIVED  
SACRAMENTO  
CVRWQCB

12 SEP 17 PM 12:46

September 12, 2012

Guy Childs / Wendy Wyels  
California Regional Water Quality Control Board  
Central Valley Region  
11020 Sun Center Drive, Suite 200  
Rancho Cordova, California 95670-6114

RE: Holland Riverside Wastewater Treatment Facility  
– Recent Inspection and Notice of Violation

Dear Wendy and Guy,

Thank you for your report of the recent inspection and notice of violation. Please see attached photos showing that vegetation has been removed from Pond 2.

According to the Monitoring and Reporting Program No. 5-01-093 issued to Holland Riverside Marina, the type of sample for Freeboard is "Observation", not "Staff Gauge Measurement", therefore there is no violation for not installing the staff gauges. "Observation" method is preferred over "Staff Gauge Measurement" method because the pond lining will not be disturbed or damaged by using the "Observation" method. Moreover, the "Observation" method is very accurate over the past ten years due to the stable water flow and usage for our marina.

Please feel free to call us at 925-634-3822 for questions.

Sincerely,



Kevin Hinman  
President



